

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 319

Dated: 23/07/2026

It is certified that an inspection team headed by Dr. Nidhi Garg, Medical Officer

(Name of Officers with designation) from o/o BMO Dargu PHED

inspected the Arihant International School, Nahan

(Name & Address of the school) on 23-07-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 695 dated 19/8/26 / 21/8/26

of Water Testing Lab
JAL-SHAKTI VIBHAG, NAHAN (PHED Lab) certified that the

Arihant International School, Nahan (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 1 year from date of issue

Medical Officer
P.H.C Surla
District Simaur (H.P.)

Signature with Seal: Dr. Nidhi

Name: Medical Officer

Designation: o/o BMO Dargu

Name & Address of the Office / Department: o/o BMO Dargu

To Director
Arihant International School, Nahan
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

HIMACHAL PRADESH
JAL SHAKTI VIBHAG

No. JSV-NSD-Water Sample 2026-27- 830

Dated:- 21/8/26

To

Arhant International School
Nahan Distt. Sirmour H.P

Subject :- Report of Water Sample

Sir,

The Submitted water sample is tested & water sample report sent here with your information.

Encl. :- As above

Received By

Name

Dated

Sign.

Assistant Engineer
Jal Shakti Sub Division,
Nahan



TC-15382

**HIMACHAL PRADESH
WATER TESTING LABORATORY
JAL SHAKTI VIBHAG, NAHAN**

TEST REPORT

Sample No. : 695

Date:- 19/8/26

Test Report No: DWTL-NAHAN-695

Name & Address of Customer: Arihant International School, Naham

Sampling Method: N/A

Sample Description: Water

Sample Quantity: 500ml x 2

Collected on: 19/8/26

Test Start Date: 19/8/26

Test End Date: 21/8/26

Condition of Sample When Received: OK

Name of Source/Scheme: -

Name of Panchayat: Naham

Name of Village: -

Name of Habitation: Arihant International School, Naham

Type of Source: Tap

Issue Date: 21/8/26

Environmental Condition: Temperature $25 \pm 2^\circ\text{C}$ & Humidity $65 \pm 15\%$ RH

Sr. No.	Test	Test Method	Result	Requirements As per IS 10500:2012	
				Acceptable Limit	Permissible limit in the absence of Alternate Source
Physical Parameters					
1.	Turbidity , NTU ,Max	IS 3025 (Part 10)	0.9 NTU	1 NTU	5 NTU
2.	Colour, Hazen units, Max	APHA 24 th Edition, 2120- Method B (Visual Comparison Method)	BDL (0L-5)	5	15
3.	Odour	IS-3025 (Part 5)	Agreeable	Agreeable	Agreeable
4.	Taste	IS-3025 (Part 7)	Agreeable	Agreeable	Agreeable
5.	pH value	APHA 24 th Edition, 4500 - H ⁺ Method B (Electrometric Method)	7.46	6.5-8.5	No relaxation
6.	Total Dissolved Solids mg/l, Max	APHA 24 th Edition, 2540- C (Total Dissolved Solids Dried at 180 ^o C)	374 mg/l	500 mg/l	2000 mg/l
Chemical Parameters					
7.	Total Alkalinity (as CaCO ₃), mg/l, Max	IS 3025 (Part 23)	84 mg/l	200 mg/l	600 mg/l
8.	Chloride (as Cl), mg/l, Max	IS3025 (Part 32)	32.61 mg/l	250 mg/l	1000 mg/l
9.	Total Hardness (as CaCO ₃), mg/l, Max	IS 3025 (Part 21)	170 mg/l	200 mg/l	600 mg/l
10.	Calcium (as Ca), mg/l, Max	APHA 24 th Edition, 3500 - Ca Method B (EDTA Titrimetric Method)	40.08 mg/l	75 mg/l	200 mg/l
11.	Magnesium (as Mg), mg/l, Max	APHA 24 th Edition, 3500 Mg-B (Calculation Method)	17.01 mg/l	30 mg/l	100 mg/l

Remarks (if any) BDL= Below Detection Limit; DL= Detection Limit

Note:

- This report should not be produced partly or full without approval of signatory authority for legal purpose.
- The results refer only to tested samples and parameters tested.
- Samples will be stored for a period of 7 days from the date of issue of report

END OF REPORT

Tested By: *[Signature]*
Assistant Chemist
Water Testing Laboratory, Naham

[Signature]
Authorized Signatory
Sumit Goyal
Water Testing Laboratory, Naham



HIMACHAL PRADESH
WATER TESTING LABORATORY
JAL SHAKTI VIBHAG, NAHAN

TEST REPORT

Sample No.: BL-695 Date: 19/8/26

Test Report No.: DWTL-NAHAN BL-695
Name & Address of Customer: Adihant International School Nahan
Sampling Method: N/A
Sample Description: Water
Sample Quantity: 500 ml X 2
Collected on: 19/8/26
Test Start Date: 19/8/26
Test End Date: 21/8/26

Condition of Sample When Received: OK
Name of Source/Scheme: Nahan
Name of Panchayat: Nahan
Name of Village: Adihant International School Nahan
Name of Habitation: Adihant International School Nahan
Type of Source: Tap
Issue Date of Test Report: 21/8/26

Environmental Condition: Temperature $25 \pm 2^\circ\text{C}$ & Humidity $65 \pm 15\%$ RH

Sr. No.	Test	Test Method	Result	Requirements As per IS 10500:2012	
				Acceptable Limit	Permissible limit in the absence of Alternate Source
1.	Total Coliform	IS 15185	<u>Absent/100ml</u>	Absent/100 ml	-
2.	E. Coli	IS 15185	<u>Absent/100ml</u>	Absent /100 ml	-

Note:

- This report should not be produced partly or full without approval of signatory authority for legal purpose.
- The results refer only to tested samples and parameters tested.

-----END OF REPORT-----

Shivani
Prepared By
Laboratory Assistant
Water Testing Laboratory, Nahan

Manisha
Authorized Signatory
Manisha Verma
Water Testing Laboratory, Nahan

HIMACHAL PRADESH
WATER TESTING LABORATORY
JAL SHAKTI VIBHAG, NAHAN

TEST REPORT

Sample No. : **695**

Date:- **19/8/26**

Test Report No: DWTL-NAHAN- **695**

Name & Address of Customer: **Arvihan International School, Naham.**

Sampling Method: **N/A**

Sample Description: **Water**

Sample Quantity: **500ml x 2**

Collected on: **19/8/26**

Test Start Date: **19/8/26**

Test End Date: **21/8/26**

Environmental Condition: Temperature $25 \pm 2^{\circ}\text{C}$ & Humidity $65 \pm 15\%$ RH

Condition of Sample When Received: **OK**

Name of Source/Scheme: **—**

Name of Panchayat: **Naham**

Name of Village: **—**

Name of Habitation: **Arvihan International School, Naham**

Type of Source: **Tap**

Issue Date: **21/8/26**

Sr. No.	Test	Result	Requirements As per IS 10500:2012	
			Acceptable Limit	Permissible limit in the absence of Alternate Source
	Physical Parameters			
1.	Temperature	24.4°C	-----	-----
	Chemical Parameters			
2.	Nitrate (as NO ₃) , mg/l, Max	0.0 mg/l	45 mg/l Max	No relaxation
3.	Fluoride (as F) , mg/l, Max	0.0 mg/l	1.0 mg/l Max	1.5 mg/l Max
4.	Sulphate (as SO ₄) , mg/l, Max	—	200 mg/l Max	400 mg/l Max
5.	Ammonia(as total ammonia –N) , mg/l, Max	—	0.5 mg/l Max	No relaxation
6.	Iron (as Fe) , mg/l, Max	—	1.0 mg/l Max	No relaxation
7.	Manganese (as Mn) , mg/l, Max	0.0 mg/l	0.1 mg/l Max	0.3 mg/l Max
8.	Total Arsenic (as As) , mg/l, Max	0.0 mg/l	0.01 mg/l Max	No relaxation
9.	Free Residual Chlorine , mg/l, Min	0.0 mg/l	0.2 mg/l	1.0 mg/l

----- END OF REPORT -----

Divani
Prepared By
Laboratory Assistant
Water Testing Laboratory, Naham

Mur 7
Assistant Chemist
Water Testing Laboratory
Nahan (H.P)